# **RO Water Harvesting**

# MRHT

#### 10<sup>th</sup> October 2017

Eeidhmeannacht na Seirbhíse Sláinte

Health Service Executive

Midland Area


Midland Regional Hospital Tullamore

#### **Tullamore Hospital Campus**



Feidhmeannacht na Seirbhíse Sláinte Health Service Executive Midland Area

Midland Regional Hospital Tullamore



# Utilities

- MV Electrical supply; MIC 1,300kVA
- 3 x 3,000kW natural gas fired LPHW boilers
- 3 separate connections to council water supply
- Central Duplex ion exchange water softener (70m<sup>3</sup>/side)
- Trend BMS system on dedicated LAN with circa 85 o/s.
- 40 Air Handling Units; 2no 200kW chillers
- 4no under-floor heating circuits
- 80 radiator circuits (3 port weather compensation)
- 10 no DHW calorifiers



Midland Regional Hospital Tullamo

#### **Utility Costs Tullamore Campus 2016** Utility Quantity 2016 Cost **Natural Gas** 6,574,424 kwhr €296,722 Electricity 6,497,600 kwhr €661,770 €166,012 Water 68,600m<sup>3</sup> €1,124,504 Total Midland Regional Hospital Paul Maloney October 2017 Feidhmeannacht na Seirbhíse Sláinte Midland Are Tullamore Health Service Executive


#### **Purified Water Systems Healthcare**


- Final rinse supply to W/D & Autoclave (HSSD)
- Renal Dialysis
- Endoscope Re-processing
- Pathology Lab Analysers (DI water)
- Water Feed Steam Boilers





#### **Reverse Osmosis**





# **RO Water Consumption MRHT**

System	Raw Water Intake	Reject Water
Renal	50m <sup>3</sup>	25m <sup>3</sup>
HSSD	12m <sup>3</sup>	8.4m <sup>3</sup>
Pathology	8.0m <sup>3</sup>	2.4m <sup>3</sup>

Feidhmeannacht na Seirbhíse Sláinte Midland Area Health Service Executive

Midland Regional Hospital Tullamore

#### **Existing Infrastructure #1**

- Sluice Water System (SWS) tanks & down services to all wards
- Complete segregation from CWS
- Daily consumption ~3m<sup>3</sup>/day
- Only included Dirty Utility cold feeds
- 231 cold fill cisterns (connected to CWS)





### **Existing Infrastructure #2**

Litres per flush	8 litres
No of flushes per 24 hr period (estimate)	15
No of flushes per WC per annum	5,475
Total number of flushes all WC's per annum	1,264,725
Average daily WC water usage (m <sup>3</sup> )	28m <sup>3</sup>
Annual WC water consumption	10,118m <sup>3</sup>
Total sluice water usage p.a.(projected) m <sup>3</sup>	1,300m <sup>3</sup>
Total per annum water usage (m <sup>3</sup> )	11,418m <sup>3</sup>



Midland Regional Hospital Tullamore

#### **Proposal**

- Fit manufacturer high recovery kit to HSSD RO. (500 litre/ hr. raw water saving).
- Lab DI not economically viable to recover
- **Recover renal reject water to SWS and transfer 231** cisterns to SWS supply



eidhmeannacht na Seirbhíse Slá Health Service Executive



Midland Regional lospital **Fullamor** 


#### **Design Requirements Renal Recovery**

- Design Flow rate 1,000 litres/hr
- Maintain air gap with Renal RO system
- Excess unwanted water flow to drain unhindered
- Fully automatic with fault reporting (BMS)
- Run dry and flood protection
- Fault redundant
- **Reject unsuitable water** (Hot water from thermal disinfection and brine back wash).
- Transfer cisterns to SWS system.





#### Water Harvesting Line Diagram



# **Costs and ROI**

Item	Cost (incl. VAT)
Copper and ancillaries for pipe work install from renal water to SWS tank	€1,436.31
Copper and ancillaries to convert 231 cisterns from CWS to SWS	€4,873.44
Stainless Steel sump tank & hopper	€850.00
500 litre intermediate storage tank c/w duty standby pumps & controller	€3,140.00
Submersible pump c/w barrel float	€271.00
Electrical control panel c/w PLC, overloads etc	€1,380.00
Electrical cabling and ancillaries	€304.15
ABS piping for connection between sump tanks intermediate storage tank	€276.75
Total	€12,531.65

- Projected daily recovery ~25m<sup>3</sup>/day
- $\therefore \in 2.42/\text{m}^3 \ge 25 \ge 365 = \notin 22,082.50$
- ROI: €12,531.65/€22,082.50 =0.56 *years* (~7 *months*)





# **As Installed**









Midland Regional Hospital Tullamore











### Learnings

- Actual water recovered 16-20m <sup>3</sup>/day (vs. projected 25m<sup>3</sup>/ day)
- Reliable & simple design (low maintenance)
- Cistern usage closer to 30 flushes/day (only 140 WCs' transferred)
- Installation can be managed through internal resources
- Potential for blending reject water back to CWS could be explored



Midland Regional Hospital Tullamore

